

ALASKA ENERGY AUTHORITY

Date: October 14, 2020

Project: **Emergency Inventory
Maintenance Engines**

Solicitation No.: 21036

Addendum No. Three

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,



Lois Lemus
Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages ONE
Addendum No. Three	Date Addendum Issued: October 14, 2020	
Issuing Office Lois Lemus Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3909 Fax: (907) 771-3044	Previous Addenda Issued Addendum #1, dated 10/9/2020 Addendum #2, dated 10/13/2020	
Project: Emergency Inventory Maintenance Engines Solicitation No.: 21036	Date and Hour Bids Due: October 20, 2020 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

Item #1 Bids are now due October 20, 2020 @ 2:00 pm

QUESTIONS AND ANSWERS

1. **Question:** Air charge air cooled engines allowed?

Answer: Charge air coolers will be allowed but they still have to abide by 26 32 13.20 2.2

The intent of the enclosed gensets (26 32 13.20) is to quickly deploy and install them onsite to get the power back on in the community. After that it is the community's responsibility to replace or rebuild one of their engines inside the power plant so that power can be produced from the community power plant. After the community has gotten their power plant in working order AEA would ship the emergency genset back to Anchorage and get it ready for the next emergency.

END OF ADDENDUM