



May 27, 2015

Invitation to Bid 15131 – Addendum 4
Construction on behalf of Edna Bay Community,
Bulk Fuel Upgrade

No Change - Submission of Bids

Bidders shall submit sealed bids in single (1) copy. All Bids including any modifications or withdrawals shall be received prior to the bid opening; bids will be publically opened at Authority's Office on **May 28, 2015 at 2:00 p.m. Alaska time**. Willow Conference Room.

Addendum 4 is issued to answer the following questions:

1) Sheet E6 #4, is the fence to be bonded every 20' to the ground ring?

Answer: Bond fence to ground ring in locations shown on plan view (1/E6) only.

2) Are Bunrdy irreversible crimps an acceptable alternate to Cadweld?

Answer: Yes

3) Are substitutions acceptable to the generator manufacturer? Kohler does not have a sales team in AK as of December.

Answer: Yes

4) Please acknowledge all addenda on the Bid Schedule.

All other terms and conditions remain unchanged.

Thank you for your interest in this bid.

Very truly yours,
Althea S. Clapp
Sr. Contracting Officer
aclapp@aidea.org

End of Addendum 4, Page 1 of 1