

Date: **April 1, 2025**
 Project: **Kipnuk Transformers and H Piles**
 Solicitation No.: **RFQ 25043**
 Addendum No.: **01**

TO ALL PLAN HOLDERS:

The following changes, additions, clarifications, and/or deletions are hereby made a part of the RFQ Documents for the above noted project, fully and completely as if the same were fully contained therein. All other terms, conditions, and specifications of the original Request for Quotes remain unchanged.

This addendum must be acknowledged by email.

The modifications directed by this Addendum One are described on this page.

CHANGES TO DOCUMENTS:

The RFQ Package is hereby clarified, changed, or modified by the following:

- Question:** Would you please provide clarification about the 50kVA 3-phase transformer requested on RFQ 25043? Are they wanting 3x 50kVA (150kVA 3-phase bank) or expecting to make 50kVA total out of a 3-phase bank? The later alternative is highly unlikely b/c a manufacturer would have to custom engineer and produce 17.5kVA polemounts.

7	50 kVA Transformer	Three	12470/ 7200 Grounded Wye	208/120 Ground Wye
---	--------------------	-------	-----------------------------------	--------------------------

Answer: 3x 50kVA 150kVA 3-phase bank.

END OF ADDENDUM #01