



Date: **April 23, 2026**
Project: **Bradley Lake Expansion 3 Phase Transformer**
Solicitation No.: **ITB 26059**
Addendum No.: **2**

TO ALL PLAN HOLDERS:

The following changes, additions, clarifications, and/or deletions are hereby made part of the ITB Documents for the above noted project, as if fully contained therein. All other terms, conditions, and specifications of the original Invitation to Bid remain unchanged.

Bidders must acknowledge receipt of this Addendum by email prior to the bid due date and time.

The ITB Package is hereby clarified, changed or modified by the following:

CONTRACT PROVISIONS AND SPECIFICATIONS

1. **Correction to ITB Number**
References in the solicitation documents to ITB No. 26037 and ITB No. 26057 are incorrect. All such references shall be replaced with the correct number: ITB No. 26059.
2. **Correction to Appendix C Terminology**
Appendix C contains incorrect references to "RFQ." These shall be corrected as follows:
 - Page 26, Section 1.3: Replace "RFQ" with "ITB."
 - Page 32, Section 3.3: Replace "RFQ" with "ITB."
3. **Appendix C, Section 3.2** (Loss Evaluation), page 30 of the solicitation is hereby revised to correct the units associated with transformer losses. The formula for Evaluated Price remains unchanged. The definitions of the variables are revised as follows:

TC = Transformer Cost

EL = No Load Loss (in kilo-Watts)

LL = Full Load Loss (in kilo-Watts)

A = No Load Loss Value (in \$/kilo-Watt) = \$0.281/kilo-Watt

B = Full Load Loss Value (in \$/kilo-Watt) = \$0.281/kilo-Watt

All proposers shall use these corrected units when preparing and submitting bids.

The bid due date and time of May 1, 2026, at 2:00 PM AKST remains unchanged.

END OF ADDENDUM #2