

ALASKA ENERGY AUTHORITY
VILLAGE POWER SYSTEM ASSESSMENT

Community: Unalakleet
Evaluation Date: Sept 14, 2012 Time Started 3:00p Completed 7:00p
Evaluator(s): Kris Tolson

*** Indicates that only one from the group shall be chosen. Otherwise choose all that apply**

Powerhouse Building

Site Location

- ☒ Site suitable for powerhouse
- ☐ < 100 feet from a public well
- ☐ < 25 feet from an eroding bank or beach, or in a flood plain

*** Foundation**

- ☒ Powerhouse on acceptable foundation (pad & post, piling, concrete, etc.)
- ☐ Powerhouse directly on gravel pad or light timbers (raised timbers, on permeable gravel)
- ☐ Powerhouse directly on tundra or natural soils (no foundation)
- ☐ Powerhouse leaning considerably or unstable foundations (seismic hazard)

*** Flooring**

- ☒ Welded steel deck plate or concrete (sealed)
- ☐ Steel deck plate or concrete (unsealed)
- ☐ Wood (sealed or painted)
- ☐ Wood (non-sealed or bare)

*** Interior Walls**

- ☒ Concrete or metal skin
- ☐ Fiberglass reinforced paneling (FRP)
- ☐ Gypsum board
- ☐ Wood (painted or sealed)
- ☐ Wood (non-painted or bare)

*** Exterior Walls**

- ☒ Concrete or metal siding
- ☐ Wood (painted or sealed)
- ☐ Wood (non-painted or bare)

* Roof Penetration

- ☒ None
- ☐ Properly installed (rain tight)
- ☐ Minor leaks (repairable)
- ☐ Major leaks (not repairable)

* Ventilation

- ☒ Proper ventilation (air intake & exhaust fans, louvers & hoods)
- ☐ Adequate ventilation (air intake & exhaust fans)
- ☐ Minimum ventilation (air intake)
- ☐ No ventilation (doors or windows have to be left open)

* Lighting

- ☒ Excellent lighting
- ☐ Adequate lighting
- ☐ Poor lighting
- ☐ No lighting

Security

- ☐ Powerhouse fenced in & door locks
- ☐ Door locks
- ☒ No fence
- ☐ No door locks

Generator Equipment and Installation

Diesel Engines

	Unit #1	Unit #2	Unit #3	Unit #4	Unit # 5
kW	455kW	455kW	455kW	455kW	_____
Hours of Operation	8400	8366	14176	10096	_____

* Generator Condition

	Unit #1	Unit #2	Unit #3	Unit #4	Unit #5
Good, like new	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fair	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Poor, guards/covers missing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Load Sizing

- ☒ Properly sized generation to meet the community loads
- ☐ Undersized generation to meet the community loads
- ☐ Oversized generation to meet the community loads

* Load Balance

- ☐ <10% Imbalance
- ☒ 10% to 25% Imbalance
- ☐ >25% Imbalance

* Control Switchgear

- ☒ Fully automatic synchronizing switchgear
- ☐ Semi-automatic synchronizing switchgear
- ☐ Manually synchronizing switchgear
- ☐ Manual transfer switches
- ☐ Manual mounted breakers

* Electrical

- ☒ Wiring appears appropriate
- ☐ Exposed wiring, improper grounding, missing covers etc.

* Fuel System Inside Powerhouse

- ☒ Welded piping
- ☐ Welded & threaded piping
- ☐ Threaded piping
- ☐ Rubber hose

Fuel System Appurtenances

- ☐ No day-tank
- ☐ Additional for active leaks

Totalizing & Station Service Meter

- ☒ Properly installed and working totalizing & station service meter
- ☐ No totalizing meter
- ☐ No station service meter

*** Fuel Meter**

- ☒ Properly installed & working fuel meter
- ☐ No fuel meter

Environmental

Interior of Powerhouse

- ☒ Clean, well-kept
- ☐ Old generator part stored inside facility
- ☐ Waste oil stored inside facility
- ☐ Apparent oil spills

Under Facility

- ☒ Clean, well-kept
- ☐ Old generator part stored under facility
- ☐ Waste oil stored under facility
- ☐ Apparent oil spills

Surrounding of Powerhouse

- ☐ Clean, well-kept
- ☒ Old generator part stored on site
- ☐ Waste oil stored on site
- ☐ Apparent oil spills

*** Waste Oil Disposal**

- ☐ Waste oil blending system
- ☒ Waste oil incinerator
- ☐ Drum or tank storage for waste oils

*** Life, Health, & Safety**

- ☒ Code Compliant
- ☐ Low risk
- ☐ Medium risk
- ☐ High risk
- ☐ Potential for loss of life

Electrical Distribution Line Evaluation

Overhead Distribution System

* Pole type

- ☒ Fully treated poles
- ☐ Butt treated poles
- ☐ Native pole (trees)

* Pole installation

- ☐ Proper depth (can be determined by the manufacture's mark or button on pole)
- ☒ Within 12 inches of recommended depth
- ☐ Within 24 inches of recommended depth
- ☐ Greater than 24 inches of recommended depth

* Pole alignment

- ☒ Poles straight
- ☐ Poles leaning less than 10°
- ☐ Poles leaning greater than 10°

* Distribution voltage

- ☒ =>7200 volts
- ☐ 2400 volts
- ☐ 480/277 volts
- ☐ 208/120 volts

* Anchors

- ☐ Properly installed (<12 inches of the anchor rod exposed)
- ☒ 12 - 24 inches of the anchor rod exposed
- ☐ >24 inches of the anchor rod exposed

* Primary conductor

- ☒ Appears properly installed (sag, conductor size, etc)
- ☐ Improperly installed (conductor needs resagging, etc)

* Service conductor

- ☒ Appears properly installed (sag, conductor size, etc)
- ☐ Improperly installed (conductor needs resagging, etc)

*** Meter installation**

- ☒ Appears to be properly installed (height, grounding, etc)
- ☐ Improperly installed (height, no ground, etc)

*** Meter Condition Residential & Commercial**

- ☒ Good (appears in good condition)
- ☐ Fair (minor corrosion)
- ☐ Poor (major corrosion, needs replacing)

*** Over all condition of the system**

- ☒ Excellent (no repairs needed)
- ☐ Good (minor repairs, re-sag guys, re-sag service drops, etc.)
- ☐ Poor (major repairs needed, pole, guy, conductor, meter replacement, etc)

Underground Distribution System

*** Primary conductor**

- ☒ Appears to be properly installed
- ☐ Exposed conductor

*** Transformers**

- ☒ Appears to be properly installed
- ☐ Improperly installed (no pad, leaning, etc)

*** Service conductor**

- ☒ Appears to be properly installed
- ☐ Exposed conductor

Operator Proficiency

* Meter Reading

- ☒ Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

* Daily Logs

- ☒ Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

* Routine Maintenance

- ☐ Excellent
- ☒ Good
- ☐ Acceptable
- ☐ Unacceptable

* Scheduled Maintenance

- ☒ Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

* Maintenance Planning

- ☐ Excellent
- ☒ Good
- ☐ Acceptable
- ☐ Unacceptable

Waste Heat Recovery

* Waste Heat Recovery Operational

☒ Yes

☐ No

List current users

BSSD / City Shop / Water Plant/ City Trash Bailer

* BTU/Hr Meter

☒ Yes

☐ No

* Additional Waste Heat Available

☒ No

☐ Yes

List Potential New Users

System Information

Supply / Return Delta T

10deg F

Estimate of current annual heating fuel gallons displaced

Unknown

Estimate of potential annual heating fuel gallons displaced

Unknown

Existing Heat Sales Agreement(s)

BSSD / City

General Questions

Use separate sheet(s) to answer these questions.

1. If records are available, indicate the number, duration, and causes of all forced outages during the last 12 months. If records are not available, provide whatever reasonable estimates available from utility personnel regarding outages number, duration, and causes. **Not Available**

ALASKA ENERGY AUTHORITY

VILLAGE POWER SYSTEM INVENTORY

DATE	Sept 14, 2012	TIME START	3:00p	TIME END	7:00p
COMMUNITY	Unalakleet	UTILITY	Unalakleet Valley Elec Coop		
OWNERSHIP	UVEC	CONTACT	Reese Hutha		
OPERATOR	Henry Nielsen	PHONE	907.624.3117		

	G-1	G-2	G-3	G-4	G-5
ENGINE MAKE	Caterpillar	Caterpillar	Caterpillar	Caterpillar	
ENGINE MODEL	3456	3456	3456	3456	
ENGINE RPM	1800	1200	1800	1800	
SERIAL NUMBER	7WG03643	7WG03325	7WG03170	7WG03534	
GOVERNOR TYPE	Cat Electronic	Cat Electronic	Cat Electronic	Cat Electronic	
MODEL ACTUATOR	--	--	--	--	
MODEL SPEED CONTROL	--	--	--	--	
DC VOLTAGE	24VDC	24VDC	24VDC	24VDC	
UNIT CIRCUIT BREAKER	GE	GE	GE	GE	
TYPE/AMP/VOLT	800A / 600V	800A / 600V	800A / 600V	800A / 600V	
CURRENT HOURS	8400	8366	14178	10098	
GENERATOR MAKE	Caterpillar	Caterpillar	Caterpillar	Caterpillar	
GENERATOR MODEL #	LC6124G	LC6124G	LC6124G	LC6124G	
GENERATOR SERIAL #	L6B02786	HCIG0093	CCIG00790	JCIG01024	
GENERATOR CAPACITY (kW)	455kW	455kW	455kW	455kW	
GENERATOR VOLTAGE	480	480	480	480	
VOLTAGE REGULATOR, MAKE & MODEL	Caterpillar CDVR	Caterpillar CDVR	Caterpillar CDVR	Caterpillar CDVR	
PARALLEL SWITCH GEAR (Y or N)	Y	Y	Y	Y	
kWh METER(Yes or No)	Y				
POWERHOUSE kWh METER TYPE	SATEC				
CATALOG # or TYPE	PM172E				
DEMAND ?	--				
CT RATIO	1200:5				
STATION SERVICE METER (Yes or No)	Yes				
STATION SERVICE METER TYPE	SATEC				
CATALOG # or TYPE	PM172E				
BATT. CHARGER/TYPE/MODEL	SENS NRG24-20-RCLS				
FUEL DAY TANK TYPE	500 gal custom				
PUMP #	Oberdorfer N994RH-340				
MOTOR #	Baldor M13A-101781105-005				
FUEL DAY TANK METER	Contoil 180373				
FIRE PROTECTION					
TYPE/OPERATIONAL?	Water Mist/ . operable				
ORIGINAL CONTRACTOR					