

**ALASKA ENERGY AUTHORITY
VILLAGE POWER SYSTEM ASSESSMENT**

Community: CHITINA
Evaluation Date: 6/24/2012 Time Started 3:00 PM Completed 6:00 PM
Evaluator(s): BRIAN WHETSTONE

*** Indicates that only one from the group shall be chosen. Otherwise choose all that apply**

Powerhouse Building

Site Location

- X Site suitable for powerhouse
☐ < 100 feet from a public well
☐ < 25 feet from an eroding bank or beach, or in a flood plain

*** Foundation**

- X Powerhouse on acceptable foundation (pad & post, piling, concrete, etc.)
☐ Powerhouse directly on gravel pad or light timbers (raised timbers, on permeable gravel)
☐ Powerhouse directly on tundra or natural soils (no foundation)
☐ Powerhouse leaning considerably or unstable foundations (seismic hazard)

*** Flooring**

- X Welded steel deck plate or concrete (sealed)
☐ Steel deck plate or concrete (unsealed)
☐ Wood (sealed or painted)
☐ Wood (non-sealed or bare)

*** Interior Walls**

- X Concrete or metal skin
☐ Fiberglass reinforced paneling (FRP)
☐ Gypsum board
☐ Wood (painted or sealed)
☐ Wood (non-painted or bare)

*** Exterior Walls**

- X Concrete or metal siding
☐ Wood (painted or sealed)
☐ Wood (non-painted or bare)

* Roof Penetration

- X None
☐ Properly installed (rain tight)
☐ Minor leaks (repairable)
☐ Major leaks (not repairable)

* Ventilation

- X Proper ventilation (air intake & exhaust fans, louvers & hoods)
☐ Adequate ventilation (air intake & exhaust fans)
☐ Minimum ventilation (air intake)
☐ No ventilation (doors or windows have to be left open)

* Lighting

- X Excellent lighting
☐ Adequate lighting
☐ Poor lighting
☐ No lighting

Security

- ☐ Powerhouse fenced in & door locks
X Door locks
X No fence
☐ No door locks

Generator Equipment and Installation

Diesel Engines

	Unit #1	Unit #2	Unit #3	Unit #4	Unit # 5
kW	117 KW	117 KW	67 KW	_____	_____
Hours of Operation	11531 hrs	10474 hrs	2011 hrs	_____	_____

* Generator Condition

	Unit #1	Unit #2	Unit #3	Unit #4	Unit #5
Good, like new	X	X	X	<input type="checkbox"/>	<input type="checkbox"/>
Fair	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Poor, guards/covers missing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Load Sizing

- X Properly sized generation to meet the community loads
☐ Undersized generation to meet the community loads
☐ Oversized generation to meet the community loads

* Load Balance

- X <10% Imbalance
☐ 10% to 25% Imbalance
☐ >25% Imbalance

* Control Switchgear

- X Fully automatic synchronizing switchgear
☐ Semi-automatic synchronizing switchgear
☐ Manually synchronizing switchgear
☐ Manual transfer switches
☐ Manual mounted breakers

* Electrical

- X Wiring appears appropriate
☐ Exposed wiring, improper grounding, missing covers etc.

* Fuel System Inside Powerhouse

- X Welded piping
☐ Welded & threaded piping
☐ Threaded piping
☐ Rubber hose

Fuel System Appurtenances

- X No day-tank
☐ Additional for active leaks

Totalizing & Station Service Meter

- X Properly installed and working totalizing & station service meter
☐ No totalizing meter
☐ No station service meter

*** Fuel Meter**

- X Properly installed & working fuel meter
☐ No fuel meter

Environmental

Interior of Powerhouse

- X Clean, well-kept
☐ Old generator part stored inside facility
☐ Waste oil stored inside facility
☐ Apparent oil spills

Under Facility

- X Clean, well-kept
☐ Old generator part stored under facility
☐ Waste oil stored under facility
☐ Apparent oil spills

Surrounding of Powerhouse

- X Clean, well-kept
☐ Old generator part stored on site
☐ Waste oil stored on site
☐ Apparent oil spills

*** Waste Oil Disposal**

- ☐ Waste oil blending system
☐ Waste oil incinerator
X Drum or tank storage for waste oils / **WASTE OIL DISPOSED OF EVERY 3 MONTHS**

*** Life, Health, & Safety**

- ☐ Code Compliant
X Low risk
☐ Medium risk
☐ High risk
☐ Potential for loss of life

Electrical Distribution Line Evaluation

Overhead Distribution System

* Pole type

- X Fully treated poles
- ☐ Butt treated poles
- ☐ Native pole (trees)

* Pole installation

- X Proper depth (can be determined by the manufacture's mark or button on pole)
- ☐ Within 12 inches of recommended depth
- ☐ Within 24 inches of recommended depth
- ☐ Greater than 24 inches of recommended depth

* Pole alignment

- X Poles straight
- ☐ Poles leaning less than 10°
- ☐ Poles leaning greater than 10°

* Distribution voltage

- X =>7200 volts
- ☐ 2400 volts
- 480/277 volts
- ☐ 208/120 volts

* Anchors

- X Properly installed (<12 inches of the anchor rod exposed)
- ☐ 12 - 24 inches of the anchor rod exposed
- ☐ >24 inches of the anchor rod exposed

* Primary conductor

- X Appears properly installed (sag, conductor size, etc)
- ☐ Improperly installed (conductor needs resagging, etc)

* Service conductor

- X Appears properly installed (sag, conductor size, etc)
- ☐ Improperly installed (conductor needs resagging, etc)

*** Meter installation**

- X Appears to be properly installed (height, grounding, etc)
☐ Improperly installed (height, no ground, etc)

*** Meter Condition Residential & Commercial**

- X Good (appears in good condition)
☐ Fair (minor corrosion)
☐ Poor (major corrosion, needs replacing)

*** Over all condition of the system**

- ☐ Excellent (no repairs needed)
X Good (minor repairs, re-sag guys, re-sag service drops, etc.)
☐ Poor (major repairs needed, pole, guy, conductor, meter replacement, etc)

Underground Distribution System

*** Primary conductor**

- X Appears to be properly installed
☐ Exposed conductor

*** Transformers**

- X Appears to be properly installed
☐ Improperly installed (no pad, leaning, etc)

*** Service conductor**

- X Appears to be properly installed
☐ Exposed conductor

Operator Proficiency

*** Meter Reading**

- X Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

*** Daily Logs**

- X Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

*** Routine Maintenance**

- X Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

*** Scheduled Maintenance**

- X Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

*** Maintenance Planning**

- X Excellent
- ☐ Good
- ☐ Acceptable
- ☐ Unacceptable

Waste Heat Recovery

* Waste Heat Recovery Operational

X Yes

☐ No

List current users

HEALTH CLINIC

* BTU/Hr Meter

X Yes

☐ No

* Additional Waste Heat Available

X No

☐ Yes

List Potential New Users

System Information

Supply / Return Delta T-----**10 deg F**

Estimate of current annual heating fuel gallons displaced

Unknown

Estimate of potential annual heating fuel gallons displaced

Unknown

Existing Heat Sales Agreement(s)

Unknown

General Questions

Use separate sheet(s) to answer these questions.

1. If records are available, indicate the number, duration, and causes of all forced outages during the last 12 months. If records are not available, provide whatever reasonable estimates available from utility personnel regarding outages number, duration, and causes. **NOT AVAILABLE**

ALASKA ENERGY AUTHORITY VILLAGE POWER SYSTEM INVENTORY

DATE	6/24/2012	TIME START	2:00 PM	TIME END	6:00 PM
COMMUNITY	CHITINA	UTILITY	CHITINA ELECTRIC INC.		
OWNERSHIP	CHITINA ELEC. INC.	CONTACT	Danny		
OPERATOR	DANNY	PHONE	907-823-2220		

	G-1	G-2	G-3	G-4	G-5
ENGINE MAKE	JOHN DEERE	JOHN DEERE	JOHN DEERE		
ENGINE MODEL	4045HF485	4045HF485	4045TFM75		
ENGINE RPM	1800	1800	1800		
SERIAL NUMBER	PE4045L037240	PE4045L037241	PE4045T797387		
GOVERNOR TYPE	JD Electronic	JD Electronic	JD Electronic		
MODEL ACTUATOR	--	--	--		
MODEL SPEED CONTROL	--	--	--		
DC VOLTAGE	12 V	12 V	12 V		
UNIT CIRCUIT BREAKER	GE	GE	GE		
TYPE/AMP/VOLT	250 A/ 600 V	250 A/ 600 V	150 A/ 600 V		
CURRENT HOURS	11531 HRS	10474 HRS	2011 HRS		
GENERATOR MAKE	STAMFORD	STAMFORD	STAMFORD		
GENERATOR MODEL #	UCI274F1L-1766	UCI274F1L-1766	UCI274C1L-1766		
GENERATOR SERIAL #	M08B301881-01	M08C303802-01	M08B301875-01		
GENERATOR CAPACITY (kW)	117 KW	117 KW	67 KW		
GENERATOR VOLTAGE	277/ 480	277/ 480	277/ 480		
VOLTAGE REGULATOR, MAKE & MODEL	Newage MX 341	Newage MX 341	Newage MX 341		
PARALLEL SWITCH GEAR (Y or N)	Y	Y	Y		
kWh METER(Yes or No)	YES				
POWERHOUSE kWh METER TYPE	SATEC				
CATALOG # or TYPE	PM172E				
DEMAND ?	YES				
CT RATIO	NOT LEGIBLE				
STATION SERVICE METER (Yes or No)	YES				
STATION SERVICE METER TYPE	SATEC				
CATALOG # or TYPE	PM172E				
BATT. CHARGER/TYPE/MODEL	Charles Industries C-CHARGER				
FUEL DAY TANK TYPE	NONE				
PUMP #	UNKNOWN				
MOTOR #	UNKNOWN				
FUEL DAY TANK METER	DIGITAL				
FIRE PROTECTION TYPE/OPERATIONAL?	HI-FOG WATER MIST FIRE PROTECTION/ SYSTEM IS OPERATIONAL				
ORIGINAL CONTRACTOR	AEA				