

Date: February 14, 2017

Project: Kwigillingok Rural Power System
Upgrade – Distribution System

Solicitation No.: 17064

Addendum No. Two

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,

Rich Wooten, CDT, CPSM

Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages One
Addendum No. TWO	Date Addendum Issued: February 14, 2017	
Issuing Office Rich Wooten, CDT, CPSM Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3019 Fax: (907) 771-3044	Previous Addenda Issued Addendum One, 2/13/2017	
Project: Kwigillingok Bulk Fuel and Rural Power System Upgrade – Distribution System Solicitation No.: 17064	Date and Hour Quotes Due: February 24, 2017 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

GENERAL – QUESTIONS & ANSWERS

- 1) **Q:** The following street lights do not have a designation (drawing sheet E1.3, Electrical Equipment Schedule) of which type they need to be (1 or 2):
 - a. Pole 1A-1A (sheet E3.1) install street light listed on staking sheet, symbol not on drawing.
 - b. Pole 1A-14A (sheet E3.3)
 - c. Pole 27 (additive #2), (sheet E3.9) install street light on staking sheet, not on drawing

A: a. Pole 1A-1A – Item #2, Electrical Equipment Schedule (Sheet E1.3).
 b. Pole 1A-14A – Item #2, Electrical Equipment Schedule (Sheet E1.3).
 c. Pole 27 - Item #1, Electrical Equipment Schedule (Sheet E1.3).

- 2) **Q:** There is a symbol and a #2 designation for a light on pole 8-17 (sheet E3.5), but that is not listed on the staking sheets as install street light.

A: Street lights are to be installed at all location as shown on the drawings.

- 3) **Q:** In specifications (Section 16451-4 transformers, 2.09 Tank) can you clarify if the tank needs to be constructed with stainless steel, or is mild steel sufficient.

A: The main tank can be mild steel but all of the other metal components need to be stainless steel.