

ALASKA ENERGY AUTHORITY

Date: June 11, 2020

Project: Kasaan Bulk Fuel Tank Fabrication

Solicitation No.: 20074

Addendum No. One

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,



Lois Lemus
Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages One
Addendum No. One	Date Addendum Issued: June 11, 2020	
Issuing Office Lois Lemus Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3909 Fax: (907) 771-3044	Previous Addenda Issued None	
Project: Kasaan Bulk Fuel Tank Fabrication Solicitation No.: 20074	Date and Hour Bids Due: June 23, 2020 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

CONTRACT PROVISIONS AND SPECIFICATIONS

- 1) Bid Date Extension: Bids will now be received June 23, 2020 at 2:00 PM Alaska prevailing time.**

QUESTIONS AND ANSWERES

Question 1: What is the proposed Point of Sale System?

Answer 1: The point of sale system is not part of this procurement. However, at this time, the planned POS system is a Gilbarco Passport Combo system.

Question 2: What is the proposed length of the retail dispenser hoses?

Answer 2: Each hose on the retail dispenser shall be 18ft long.

Question 3: The final completion date of “90 days from date of award” is not feasible given current tank fabricator work load, etc.

Answer 3: Final completion date has been revised to March 1, 2021.

Question 4: Page 7 paragraph 3 states “All pipe supports, struts, clamps, fittings, and hardware shall be stainless steel.” Is this accurate?

Answer 4: Remove and replace this sentence with the following: “All bolt on tank components shall be hot dipped galvanized. All fasteners (bolts, nuts, washers) shall be stainless steel.”

Question 5: How many conduit supports are required? Where are the conduit supports to be located?

Answer 5: It is envisioned that the majority of electrical conduit will be supported from the catwalk systems on each tank via bolt-on supports installed by others. For bidding purposes assume that tank manufacturer will be responsible for welding four 12” long unistrut sections on each tank (8 ea @ 12” long) and coated same as tank. Final locations of weld-on unistrut will be determined during shop drawing review phase.

END OF ADDENDUM