

ALASKA ENERGY AUTHORITY

DATED: July 10, 2020
RE: ADDENDUM NO. 1 TO REQUEST
FOR PROPOSALS (RFP) PACKAGE

RFP 20059
Venetie Rural Power System Upgrade (RPSU)
and Bulk Fuel Upgrade (BFU)

EMAIL TO: All RFP recipients on record.

The RFP Package is hereby clarified or changed as follows:

Question #1

Is the overall budget of \$100,000-\$250,000 for Phase 1 (CDR) or for all Phases of the project?

Answer: Phase 1 only.

Question #2

Is there a preference from the community standpoint for phasing of the potential improvements? I know that we have a distribution upgrade in the mix as well. Is there a preference as far as what the community or AEA feels is the top priority 2nd, 3rd 4th and so forth?

Answer:

Power plant will be primary and tank farm a close second

ANTHC is in the process of building a new water treatment plant and it is located near the power plant to take advantage of the heat recovery system. In your preliminary review of any maps the new power plant would need to be located relatively close to the existing power plant. ANTHC is planning on continuing to utilize the waste heat.

All other terms and conditions remain the same.

END OF ADDENDUM

We appreciate your participation in this solicitation.

Sincerely,

Lois Lemus,
Contracting Officer
907-771-3909
llemus@aidea.org