



This is not an order.

15068 - Generators Addendum 1	Attention – Althea Clapp, Sr. Contracting Officer Alaska Energy Authority (AEA) or (Authority) 813 West Northern Lights Blvd. Anchorage, AK 99503-2495 aclapp@aidea.org , Ph. 907-771-3018 Fax 907-771-3044
--	---

November 13, 2014

No Change Bid Opening	ITB shall be publically opened at, 2:30 p.m. November 26, 2014 , in the Willow Conference Room.
------------------------------	--

Please acknowledge this addendum Appendix D. Bid Schedule item 11. Acknowledge all addenda.

Addendum 1 addresses additional information listed below:

1. What are the Engine Serial Numbers

Answer: The 2-new JD 6090 serial numbers are:

RG6090G014655
RG6090G014597

We only have 1 serial number for the JD 6081 right now, both engines will be similar, AEA will be rebuilding 2, 6081 for this project.

2. What are the SAE sizing on the JD6081 engines for flywheel and flywheel housing

Answer: AEA has 1 serial number for the JD 6081 right now, both engines will be similar, AEA will be rebuilding 2, 6081 for this project.

RG6081H296676
Flywheel Housing is SAE # 1

3. What the part number of the air filter housing is that is preferred for these engines?

Answer: Per the bid specification Part 2 – Products, 2.2, H. Air Cleaners: The engine shall be provided with a dry-type, replaceable element air cleaner with a metal canister, Donaldson or equal. Open disposable type air filters or plastic canisters will not be accepted. Provide visual air restriction indicator, 20” water column limit, manual reset, Donaldson X002251, no substitutes.

End of Addendum 1. Thank you for your interest and please email me at aclapp@aidea.org if your company has additional questions of concerns.

Cordially

Althea S Clapp

Althea S. Clapp
Senior Contracting Officer