



LEGEND

- VALVE & VALVE NUMBER V12
- CHECK VALVE
- KAMLOK COUPLING
- FLEX COUPLING
- FIRE EXTINGUISHER

THE AREA SUBJECT TO COAST GUARD JURISDICTION IS THE MARINE TRANSFER AREA (PIPELINE AND HOSE) BETWEEN THE VESSEL OR WHERE THE VESSEL MOORS, AND THE FIRST MANIFOLD OR SHUTOFF VALVE ON THE PIPELINE ENCOUNTERED AFTER THE PIPELINE ENTERS THE SECONDARY CONTAINMENT AREA AROUND THE BULK STORAGE TANKS. EPA JURISDICTION EXTENDS 'INLAND' FROM THE FIRST VALVE IN THE TANK FARM.

TANK NO	TYPE	PRODUCT	GROSS CAPACITY (gals.)
1	BIA SINGLE WALL VERTICAL	HEATING FUEL	9,000
2	-	-	9,000
3	-	-	10,000
4	-	-	8,000
5	-	-	8,000
6	-	-	10,000
7	-	-	7,000
8	-	-	7,000
9	SINGLE WALL HORIZONTAL	GASOLINE	24,000
10	-	-	5,000
11	-	-	5,000
12	DOUBLE WALL HORIZONTAL	HEATING FUEL	20,000
13	-	GASOLINE	20,000
14	-	-	25,000
			167,000

FIGURE 2. SITE PLAN
4