



Date: November 5, 2021

Project: Nikolai and Venetie Power System
and Bulk Fuel Upgrade Projects

Solicitation No.: 22021

Addendum No. One

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,

DocuSigned by:
Selwin C. Ray
0A1919DCB4834AC...

Selwin C. Ray
Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages 1
Addendum No. ONE	Date Addendum Issued: November 5, 2021	
Issuing Office Selwin Ray Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3035 Fax: (907) 771-3044	Previous Addenda Issued NONE	
Project: Nikolai and Venetie Power System and Bulk Fuel Upgrade Projects Solicitation No.: 22021	Date and Hour Bids Due: December 2, 2021 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

CONTRACT PROVISIONS AND SPECIFICATIONS

Item #1- Drawings: *The drawings related to Nikolai & Venetie RPSU & BFU have been updated. Please see the new attachments.*

END OF ADDENDUM